

PLAN VIEW

SECTION A-A

REINFORCING STEEL SCHEDULE (A.S.T.M. A-615 GRADE 60)						
COLD FORM BARS TO INSIDE DIMENSIONS				A / B		
SYM	QTY	SIZE	LOCATION. DIRECTION	A	B	WGT
ST1	20	#6	FOOTERS. LATERAL	10'-0		300
ST2	4	#5	ENDS. LATERAL	10'-0		43
	20		APPROACHES. LATERAL			209
ST3	20	#5	APPROACHES. LONG.	9'-6		198
L1	20	#5	APPROACH TO END TIES	2'-3	2'-3	112

L1 GIVEN WITHOUT RISER BASEPLATES. DIMENSION "B" WILL VARY WITH THE ACTUAL HEIGHT OF RISERS USED. AS FOLLOWS:

	L1
NO RISERS	2'-3
3" RISERS	2'-6
6" RISERS	2'-9



DETAIL "L"

ANCHOR LOCATIONS (OTHER SIDE IS OPPOSITE)

DETAIL "K"

ANCHOR LOCATIONS (OTHER SIDE IS OPPOSITE)



VIEW J-J



SECTION N-N

STEEL PLATE ASSY'S (ONE EACH END)
MATERIAL: H.R. STEEL (BY OTHERS).



SECTION C-C

(TYPICAL END)



SECTION D-D

(TYP SINGLE BASEPLATE FOOTER)

MATERIAL SUMMARY* (INCLUDES FOOTERS & APPROACHES)	FOOTER DEPTH: "X" INCHES (24 INCH MINIMUM)				
	24	36	48	60	72
CONCRETE (CU. YDS.)	17	22	27	31	36
REINFORCING STEEL (LBS)	862				

* IF OPTIONAL WASHOUT SLABS ARE USED. ADD:
550 SQ. FT. OF WWF: 6x6_W1.4xW1.4
7 CU. YD. OF CONCRETE.

NOTES:

1) USE MINIMUM 3000 PSI STRENGTH CONCRETE AT 28 DAYS WITH 5-7% AIR ENTRAINMENT.
2) USE MINIMUM 60KSI YIELD DEFORMED REINFORCING STEEL. REBAR MINIMUM DEPTH OF COVER SHOULD BE IN ACCORDANCE WITH THE LATEST ACI BUILDING CODE REQUIREMENTS FOR STRUCTURAL CONCRETE (ACI 318-SECTION 7.7) UNLESS OTHERWISE SPECIFIED.
3) FOUNDATION REQUIRES 2500 PSF RATED SOIL FOR HIGHWAY TRUCK APPLICATIONS.
4) TOP OF CONCRETE AT BASEPLATE LOCATIONS TO BE LEVEL AND IN ONE PLANE ±1/8"
5) DIAGONAL MEASUREMENTS ENDWALL TO ENDWALL MUST BE EQUAL WITHIN 1/2".
6) BASEPLATE ANCHORS TO BE SUPPLIED BY METTLER-TOLEDO. USE BASEPLATES AS TEMPLATES TO LOCATE EXPANSION BOLTS DURING SCALE INSTALLATION.
7) RAMP LENGTH: -PER LOCAL REGULATIONS
-1/2" SLOPE PER FOOT TYPICAL
8) BOTTOM OF FOOTER MUST BE BELOW LOCAL FROSTLINE.
9) FOOTER HEIGHT "Y" CAN BE VARIED TO SUIT LOCAL CLEARANCE REQUIREMENTS. TOP OF FOOTER AT GRADE LEVEL, i.e. FLUSH WITH WASHOUT SLABS. PROVIDES STANDARD 3" CLEARANCE BETWEEN BOTTOM OF WEIGHBRIDGE AND WASHOUT SLABS.
10) OPTIONAL: 6" OF GRAVEL MAY BE USED UNDER APPROACHES TO IMPROVE DRAINAGE.
11) CONTRACTOR SUPPLIES:
-EXCAVATION -CONCRETE AND FORMS
-REINFORCING STEEL -1 1/2" DIA CONDUIT
-CURB ANGLE ASSEMBLIES -BUMPER PLATE ASSEMBLIES
(SECT C-C) (VIEWS J-J & N-N)

DRAWING IS TO SCALE ONLY WHEN BORDER MEASURES 22-7/8" X 35" (FULL SIZE)

REV	CHANGE	BY	DATE
A	ADDED 7561 REFERENCE TO DRAWING TITLE		
	ADDED REBAR NOTE, ST3 & L1 QTY WERE 22	HBW	06/19/00
B	ADDED VTS231 TO TITLE, PDX DETAILS, RISERS	ADF	05/25/10

SCALE .02
DATE 6/2/1999
DRN ZL APPD
TITLE VTS231/7562 FDN: VARIABLE FOOTER 60' X 10', 20' MODULES, W/ RISER OPTIONS

METTLER TOLEDO

UNLESS OTHERWISE SPECIFIED, ALL DIMENSIONS ARE IN INCHES, AND DIMENSIONAL TOLERANCES ARE:
FRACTIONAL ±1/32 DECIMAL .XX ±.02 .XXX ±.005 ANGULAR ±.5°

THIS PRINT IS FURNISHED WITH THE UNDERSTANDING THAT THE ESSENCE THEREOF WILL NOT BE REPRODUCED IN WHOLE OR IN PART WITHOUT WRITTEN AUTHORIZATION OF METTLER-TOLEDO, INC. ALL DESIGNS ARE THE PROPERTY OF METTLER-TOLEDO, INC. AND WILL BE PROTECTED BY PATENTS.

TC204087 REV B

For Reference Only. Not for Construction.